

TACO MODEL # CPV-300-2-480/80

NOTES:

1.) ___ GPM @ __ PSIG.
2.) (1) TACO VM-_____ PUMPS, ___ HP @ 3500 RPM, 460V. 3 PHASE 60 Hz.
3.) (2) TACO VM-20/2 PUMPS, 10 HP @ 3500 RPM, 460V. 3 PHASE 60 Hz.
4.) FLOW SWITCH
5.) (1) TACO CA-800-G BLADDER TANK 150# PSIG.
6.) CLA-VAL PRESSURE REDUCING VALVES ARE MODEL 91-01-AS
7.) CONTROL PANEL HARDWARE:
POWER ON LIGHT
PUMP RUN LIGHT
LOW SUCTION ALARM LIGHT
LOW SYSTEM ALARM LIGHT
HIGH SYSTEM ALARM LIGHT
H.O.A. SWITCH
ALTERNATOR CLOCK





© COPYRIGHT
THIS DRAWING IS THE PROPERTY OF NAMCO DIV. OF JOHN R. NEAL & ASSOCIATES INC. DALLAS, TEXAS ITS USE WITHOUT THE EXPRESS WRITTEN PERMISSION IS PROHIBITED.

DRAWN BY:	REVISED	APPROVED
DC	A 9/13/94	
	B	
DATE: 9/7/94	C	
SHEET: 1 OF 1	D	
SCALE: NONE	E	

THREE PUMP VM STYLE BOOSTER SYSTEM WITH HYDRO TANK

JOB NO.	SIZE	DWG NO.
	A	90-01345D

NAMCO DIV.